



## SETTING PROCEDURE FOR TEMPERATURE UNIT ON RKC CB500 CONTROLLER (CELCIUS AND FAHRENHEIT)

### Procedure

**\* Read note A before steps 3 - 7 - 10 - 13**

- 1) Press "**SET**" for 3 seconds "**ArU**" appears.
- 2) Press "**SET**" repeatedly until "**LCK**" appears.
- 3) With ( ▲ , ▼ ) keys, adjust value to **1000**.
- 4) Press "**SET**" button for 3 seconds.
- 5) Hold simultaneously "**SET**" and "**RS**" for 3 seconds. "**Cod**" appears.
- 6) Press "**SET**" repeatedly up to "**SL2**" parameter.
- 7) With ( ▲ , ▼ ) keys, adjust value to "0010" for Celsius or "0011" for Fahrenheit and press "**SET**".
- 8) Hold "**SET**" and "**RS**" for 3 seconds.
- 9) Press "**SET**".
- 10) With ( ▲ , ▼ ) keys, adjust value to:  
 "0043" for Celsius adjustment;  
 "0110" for Fahrenheit adjustment;
- 11) Hold "**SET**" for 3 seconds. "**ArU**" appears.
- 12) Press "**SET**" repeatedly until "**LCK**" appears.
- 13) With ( ▲ , ▼ ) keys, adjust value to "**0111**".
- 14) Press "**SET**" for 3 seconds.

**Important : Make sure RO stops by itself at desired temperature during first wash cycle.**

**\*Note A : The most orange figure is the one that will change.  
 Press "RS" to change the location of the digit to change.**